

Modbus Fault Log Register Table (3X/4X)

#	Time Stamp	Name of I/O/System		Fault Index	Corresponds to Virtual Output #	Reserved	
	UDINT	Length UINT	String 6 Words		UINT		
1	107	109	111	117	118	119	Most recent
2	121	123	125	131	132	133	
3	135	137	139	145	146	147	
4	149	151	153	159	160	161	
5	163	165	167	173	174	175	
6	177	179	181	187	188	189	
7	191	193	195	201	202	203	
8	205	207	209	215	216	217	
9	219	221	223	229	230	231	
10	233	235	237	243	244	245	

*See Safety Controller Manual Appendix D.4 for Column/Row Heading Descriptions